



October 28, 2005

Mr. Norman MacDonald  
FlexHead Industries Inc.  
56 Lowland Street  
Holliston, MA 01746

Dear Mr. MacDonald,

Based on the data provided and referenced below, the Division of State Architect (DSA) accepts the FlexHead commercial flexible fire sprinkler connection for use in projects within the jurisdiction of the DSA, which include public elementary and secondary schools (grades K-12), community colleges and state owned or state leased essential services buildings:

1. OSHPD approval OPA-0672 and OPA-0676,
2. California State Fire Marshal Listing #7515-1619:100,
3. Factory Mutual Approval,
4. UL Listing,
5. Factory Mutual head deployment test report dated September 20, 2005, and;
6. Seismic Qualification tests at University at Buffalo dated October 7, 2005.

This product satisfies the DSA Interpretation of Regulations (IR) documents IR A-5, Section 1.3.2 for Product Acceptance and M-3 for Metal Suspension Systems for Lay-In Panel Ceilings and should be installed in complete accordance with its listings and approvals.

Thank you for your submittal and we look forward to working with you on future projects.

Sincerely yours,

A handwritten signature in black ink, appearing to read 'William Staehlin', written over a horizontal line.

William Staehlin  
Supervising Structural Engineer