



County of Sacramento
Building Inspection Division
www.bldginspection.org

PERMIT OFFICES

Branch Center (916) 875-5296
4101 Branch Center Rd., Sacramento 95827
Downtown (916) 874-6433
827 7th St., Rm. 102, Sacramento 95814

Flexhead Industries
56 Lowland Street
Holliston, MA 01746

Attn: Mike Dooley

Subject: Sacramento County Approval of Flexhead Commercial Ceiling Sprinkler Systems

Dear Mr. Dooley,

The County of Sacramento Building Inspection Department has reviewed the submittal package you've supplied us regarding the flexible fire sprinklers and connections manufactured by Flexhead Industries.

This product, when installed per Flexhead manufacturing requirements, the local Fire department requirements, and per Uniform Building Code Standard 25-2 requirements (Section 25.202 for intermediate and heavy-duty systems and section 25.209.7) is considered satisfactory as an alternate to standard commercial sprinkler systems in the County of Sacramento.

Yours truly,

Mark Handy
Associate Engineer/Architect
County of Sacramento Building Inspection Department