

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7515-1619:100

Page 1 of 1

CATEGORY: Pipe/Fittings

LISTEE: FlexHead Industries, Inc., 56 Lowland St, Holliston, MA 01746
Contact: Peter MacDonald (508) 893-9596 FAX (508) 893-6020*

DESIGN: The following models are flexible sprinkler hose fittings with specific rated pressures as follows:
For use with ordinary, intermediate and high temperature rated automatic sprinklers.

Models 2024H, 2036H, 2048H, 2060H, and 2072H having a rated pressure of 300 psig.

Models 2024S, 2036S, 2048S, 2060S, and 2072S having a rated pressure of 175 psig.

Models 2024 24" OAL, 2036 36" OAL, 2048 48" OAL, 2060 60" OAL, and 2072 72" OAL having a rated pressure of 175 psig.

All models must consist of the following components:

- 1) Flexible Hose Sprinkler Fitting assemblies, 1 inch, NPT inlet, ½ inch NPT outlet (S or H Series) or ½ or ¾ inch NPT outlet (OAL Series) or equivalent threading, in sizes ranging from 24 inches to 72 inches nominal length.
- 2) Anchoring system in accordance with the manufacturer's installation instructions.

Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rated pressure, nominal size, and UL label.

APPROVAL: Listed as sprinkler fittings for use in accordance with the National Fire Protection Association Standard for Installation of Sprinkler Systems, NFPA 13. Refer to listee's Installation Instruction Manual for details.

09-30-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 10, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division